

INDOOR LIGHTING

DOWN LIGHT



ASTRID 210 IP 20



ASTRID 210 IP 44



ASTRID 60

TRACK



DEDALO



DOMUS

WALL-MOUNTED WITH  
INDIRECT LIGHT



DOMUS



GPF APPLIQUE

FREE  
STANDING




GPF FREE STANDING

DIFFUSED LIGHT WALL  
AND CEILING








MANTA








IRIDE

## SELECTION GUIDE

		HALOGEN SOURCES								
POWER (W)		15	25	40	60	75	100	150	200	300
DEDALO Track										
DOMUS Track										
GPF Applique GPF Earth										

DISCHARGE LAMPS		
Metal halides (POWER W)		
	70	150
GPF Applique		
GPF Earth		

COMPACT FLUORESCENT LAMPS										
POWER (W)		7	13		18		26		32	
NUMBER OF LAMPS		1	2	3	1	2	1	2	1	2
ASTRID 60										
ASTRID 210 - IP 20										
ASTRID 210 - IP 44										
MANTA										

LINEAR FLUORESCENT LAMPS					
POWER (W)		18		36	58
NUMBER OF LAMPS		1	2	1	2
IRIDE					

### PEAK PERFORMANCES

Astrid compact fluorescent lamps have the highest light emitting, greater than 69 lumen/W. They are available with both conventional and electronic supply units. The horizontal arrangement of the lamps makes the total height of the device suitable even for very low false ceilings.

		CLASSIFICATION				
		BZ METHOD	DIN 5040 METHOD	CIE METHOD	UTE METHOD	
	1 X 18 W	IP 20	BZ 4/0.6 BZ3	A 41	4/4/4/3/3/3/ 3/3/3/3/3/4	0.63D + 0.00T
	2 X 18 W		BZ 4/0.8 BZ3	A 40	5/4/4/3/3/3/ 3/3/3/3/4/4	0.61D + 0.00T
	1 X 26 W		BZ 4/0.6 BZ3	A 40	4/4/4/3/3/3/ 3/3/3/3/3/4	0.65D + 0.00T
	2 X 26 W		BZ3	A 40	4/4/3/3/3/3/ 3/3/3/3/3/4	0.63C + 0.00T
	1 X 32 W		BZ 4/0.6 BZ3	A 40	4/4/4/3/3/3/ 3/3/3/3/3/4	0.67D + 0.00T
	2 X 32 W		BZ 2/0.8 BZ 1/1 BZ 2/1.25 BZ 1	A 60	2/1/1/1/1/1/ 1/1/1/1/1/1	0.4B + 0.00T
	1 X 18 W	IP 44	BZ 2	A 60	2/2/2/1/1/1/ 1/1/1/1/1/1	0.4B + 0.00T
	2 X 18 W		BZ 2/1.25 BZ 1/4 BZ 2	A 61	2/1/1/1/1/1/ 1/1/1/1/1/1	0.4B + 0.00T
	1 X 26 W		BZ 2	A 61	2/2/1/1/1/1/ 1/1/1/1/1/1	0.42B + 0.00T
	2 X 26 W		BZ 2	A 61	2/2/2/1/1/1/ 1/1/1/1/1/2	0.39C + 0.00T
	1 X 32 W		BZ 3	A 40	4/4/3/3/3/3/ 3/3/3/3/3/4	0.63C + 0.00T

## SELECTION GUIDE

INSTALLATION COMPLIANT WITH CIE SUGGESTIONS AS TO TYPE OF ROOM, ILLUMINATION LEVEL AND GLARE CONTROL CLASS															
Type of room (CEI ref.)	HOTELS		AUDITORIUMS		LIBRARIES	SHOPS AND DEPARTMENT STORES			HOSPITALS		SCHOOLS AND UNIVERSITIES		OFFICES		
	Common rooms, eating areas		Bedrooms	Theatres and concert halls, multipurpose		Reading tables	Areas of public passage	Display of goods	Windows displays	Aisles	Aisles: reading	Classrooms and lecture halls		General, meeting rooms	Rooms with VDT
Average illumination level (lux)	100	300	300	100	200	500	200	500	750	100	200	300	500	500	300
Glare control classes	A	A	B	B	B	B	B	B	B	A	A	B	B	B	A
IP 20	1 x 18 W	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓	✓	✓
	2 x 18 W	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓	✓	✓
	1 x 26 W			✓	✓	✓	✓					✓			
	2 x 26 W	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓	✓	✓
	1 x 32 W			✓	✓	✓	✓					✓			
	2 x 32 W	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓	✓	✓
IP 44	1 x 18 W	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	2 x 18 W	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	1 x 26 W	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	2 x 26 W	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	1 x 32 W	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓